

Addendum No. 1

Owner: City of Unalaska

Project: Water Service Modifications and Wash-down Piping Project
DPW/U Project No. 41-168

Date: October 12, 2017

Please acknowledge receipt of this Addendum No. 1 in the appropriate blank on the bid form.

The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the contract documents for the subject project. In case of conflicts between this Addendum and previously issued documents, this Addendum shall take precedence.

- Item 1: The proposal documents require quotes to be submitted to the Office of the City Clerk. To clarify, sealed quotes may be submitted in person at City Hall or e-mailed to cityclerk@ci.unalaska.ak.us. Please ensure your sealed bid or email subject states "Bid Enclosed - Water Service Modifications and Wash-down Piping Project". Emailed bids also must be received in the Clerks' Office before 2:00 p.m. on November 14, 2017.
- Item 2: Paragraph I.B.ii of the work description requires that the new backflow preventer be a Watts 909 or approved equal. Substitute equal for Watts 909 is acceptable, however, the model chosen for substitution must be LEAD FREE and USC listed.
- Item 3: The one-line schematic of the work included with the proposal documents show a strainer installed between the new meter and backflow preventer. Watts offers an option with their backflow preventer to provide a strainer integral to the backflow preventer assembly. The strainer offered by Watts is acceptable for the strainer shown on the one-line schematic.
- Item 4: The one-line schematic of the work included with the proposal documents show a Pressure Reducing Valve and Strainer installed after the new backflow preventer. The Pressure Reducing Valve and Strainer are optional and not required.
- Item 5: A revised Quote Proposal Form with space to acknowledge Addenda is included as part of this Addendum No. 1.

***** END OF ADDENDUM NO. 1 *****

QUOTE PROPOSAL FORM
CITY OF UNALASKA POWERHOUSE
WATER SERVICE MODIFICATIONS AND WASH-DOWN PIPING
PROJECT

ITEM NO.	DESCRIPTION (Write Unit Bid Price in Words)	LUMP SUM TOTAL PRICE
1	WATER SERVICE MODIFICATIONS AND WASHDOWN PIPING	

Addenda Acknowledged: _____

Total Price Quote: _____

Total Price Quote (in words): _____

Company Name: _____

Name and Title (Printed): _____

Signature: _____

Date: _____

Alaska Contractor's License No. _____ Alaska Business License No. _____

Mechanical Administrator Assignee License No. _____